

To Whom It May Concern

This copy is being provided for courtesy purposes only, and does not give any person or company other than our named client a right to rely on these results. No warranties, express or implied, including the warranty of due diligence and care mentioned elsewhere, shall extend to any party other than such named client.



Report no. 10901/5818A.00.I/11
 Report date 07/Oct/2011
 Object VULCANELLO M
 Product Unleaded Gasoline
 Location MARSAXLOKK, MALTA, 31st March 1979 Installation

ANALYSIS REPORT

Sample submitted as Unleaded Gasoline
 Received Sampled by Saybolt Inspector
 Marked Shoretank 9 single tank composite after discharge M/T 'Vulcanello M'
 Date of sampling 05/Oct/2011
 Testing completed 07/Oct/2011
 Sealed Saybolt
 Lab number 5728/11

Test	Unit	Method	Specification	Result	
				Prefix	Figure
Appearance		Visual	Clear and bright	Clear and bright	
Benzene	vol%	EN 238	1.0 MX		0.61
Copper Corrosion (3hrs at 50°C)		ASTM D130	1 MX	1A	
Density at 15°C	kg/l	ASTM D4052-09	0.720 - 0.775		0.7352
Gums existent	mg/100ml	ASTM D381	5 MX		0.5
Oxidation Stability	mins	ASTM D525	360 MIN	Above	360
Lead content	g/l	ASTM D3237	0.005 MX	Below	0.001
M.O.N.		ASTM D2700	85.0 MIN		85.2
Distillation		ASTM D86			
- IBP	°C		Report		31.8
- 10% recovered	°C		Report		50.4
- 50% recovered	°C		Report		98.1
- 90% recovered	°C		Report		155.2
- FBP	°C		210.0 MX		184.5
- Residue	vol%		2.0 MX		0.2
- Evaporated at 70°C	vol%		22.0 - 50.0		29.7
- Evaporated at 100°C	vol%		46.0 - 71.0		52.8
- Evaporated at 150°C	vol%		75.0 MIN		89.0
R.V.P at 100°F - DVPE	kPa	ASTM D5191	50.0 - 80.0		78.5
R.O.N		ASTM D2699	95.0 MIN		95.2
Sulphur (*)	mass%	ASTM D2622-08	0.001 MX		0.0013
Aromatics	vol%	ASTM D1319	35.0 MX		30.7
Olefins	vol%	ASTM D1319	18.0 MX		8.1
Methanol	vol%	ASTM D5599	3 MX	Below	0.01
Ethanol	vol%	ASTM D5599	5 MX	Below	0.01
Iso-propyl alcohol	vol%	ASTM D5599	10 MX	Below	0.01
Iso-butyl alcohol	vol%	ASTM D5599	10 MX	Below	0.01
Tert-Butyl alcohol	vol%	ASTM D5599	7 MX	Below	0.01
MTBE	vol%	ASTM D5599	15 MX	Below	0.01
Other ethers containing above 5 C atoms	vol%	ASTM D5599		Below	0.01
Other oxygenates	vol%	ASTM D5599	10 MX	Below	0.01
Total oxygen	mass%	ASTM D5599	2.7 MX	Below	0.1

Precision parameters apply in the evaluation of the test results specified above. Please also refer to ASTM D3244 (except for analysis of RFG) and IP 367 with respect to the utilization of test data to